

# IMPORTANT

## Spill procedure

In the event of a spill refer to:

*Environment Management Plan.*

**IMMEDIATELY.**

### FORECOURT SPILL

Do **NOT** close the shut off valve

Once the spill is contained the valve must be closed.

Once it has been cleaned and replaced with fresh water it can be re-opened.

### TANKER FILL POINT SPILL

**IMMEDIATELY close the valve**

In the event of a TFP spill locate the blue lid (valve).

1. Lift the tee bar to full height.
2. Turn the tee bar 90 degrees in a clockwise direction.
3. Lower the tee bar.



The tee bar will now sit on the top of the blue lid instead of in the recess.

The API Separator is designed to contain a spill of 2500 litres.

For all queries with the API Separator please refer to the manual provided or contact  Management.

staff need to be familiar with the API Separator General Information and Operating Manual that each site is provided with.

# API Separator